

# Pilot study of high-performance air filtration for classroom applications

**Abstract** A study was conducted to investigate the effectiveness of three air purification systems in reducing the exposure of children to air contaminants inside nine classrooms of three Southern California schools. Continuous and integrated measurements were conducted to monitor the indoor and outdoor concentrations of ultrafine particles (UFPs), fine and coarse particulate matter (PM<sub>2.5</sub> and PM<sub>10</sub>, respectively), black carbon (BC), and volatile organic compounds. An heating, ventilating, and air conditioning (HVAC)-based high-performance panel filter (HP-PF), a register-based air purifier (RS), and a stand-alone air cleaning system (SA) were tested alone and in different combinations for their ability to remove the monitored pollutants. The combination of a RS and a HP-PF was the most effective solution for lowering the indoor concentrations of BC, UFPs, and PM<sub>2.5</sub>, with study average reductions between 87% and 96%. When using the HP-PF alone, reductions close to 90% were also achieved. In all cases, air quality conditions were improved substantially with respect to the corresponding baseline (preexisting) conditions. Data on the performance of the gas-absorbing media included in the RS and SA unit were inconclusive, and their effectiveness, lifetime, costs, and benefits must be further assessed before conclusions and recommendations can be made.

**A. Polidori, P. M. Fine, V. White, P. S. Kwon**

South Coast Air Quality Management District (AQMD),  
Diamond Bar, CA, USA

**Key words:** Air filtration; Removal effectiveness; School classrooms; Ultrafine particles; Black carbon; Volatile organic compounds.

A. Polidori  
Planning and Rules Division  
South Coast Air Quality Management District  
21865 Copley Drive  
Diamond Bar  
CA 91765-4178, USA  
Tel.: 909-396-3283  
Fax: 909-396-2099  
e-mail: apolidori@aqmd.gov

Received for review 12 May 2012. Accepted for publication 31 October 2012.

## Practical Implications

The installation of effective air filtration devices in classrooms may be an important mitigation measure to help reduce the exposure of school children to indoor pollutants of outdoor origin including ultrafine particles and diesel particulate matter, especially at schools located near highly trafficked freeways, refineries, and other important sources of air toxics.

## Introduction

Numerous epidemiological and toxicological studies have found positive associations between exposure to atmospheric particulate matter (PM) and adverse health effects (Environmental Protection Agency Integrated Science Assessments, 2009; Pope and Dockery, 2006). Although air quality standards have been established for outdoor ambient environments, a significant portion of human exposures to PM occurs indoors, where people spend around 85–90% of their time. Hence, it is important to understand and reduce the sources of both indoor and outdoor PM. Indoor PM consists of outdoor particles that have infiltrated indoors, particles emitted indoors (primary), and particles formed indoors (secondary) from precursors emitted both indoors and outdoors.

Because of their immature respiratory systems and greater breathing rates per body weight, children are particularly susceptible to potential health hazards related to PM exposure, which include asthma, lung inflammation, allergies, and other types of respiratory and cardiovascular problems (Liu et al., 2009; Patel and Miller, 2009; Schwartz, 2004). Children in California spend approximately 8% of their time in school (i.e., 4-h/day  $\times$  180 day/year), which is second only to the amount of time they spend at home (75%; Wiley et al., 1991). Thus, minimizing the concentration of PM as well as that of other air contaminants (e.g., volatile organic compounds or VOCs) inside classrooms is important, especially at schools located in close proximity to roadways and other substantial sources of air pollution.

The installation of panel filters inside the heating, ventilating, and air conditioning (HVAC) system is a

common mitigation measure to reduce the concentration of (and exposure to) indoor air pollutants. Common medium-performance filters with a Minimum Performance Reporting Value (MERV) of 7 (those installed in many U.S. commercial buildings and schools) remove only a small fraction of the particles with aerodynamic diameters ( $d$ ) lower than  $0.3\ \mu\text{m}$ , although higher reductions are generally achieved for larger particles. Diesel PM, which has recently been classified as a human carcinogen by the International Agency for Research on Cancer (IARC; Benbrahim-Tallaa et al., 2012), generally consists of particles  $<0.3\ \mu\text{m}$  and accounts for more than 80% of the total cancer risk from air toxics in the California South Coast Air Basin (MATES III Study; South Coast Air Quality Management District, 2008). New evidence also suggests that ultrafine particles (UFPs;  $d < 0.1\ \mu\text{m}$ ) have harmful health effects beyond those caused by particle mass and may be more toxic than fine particles ( $\text{PM}_{2.5}$ ;  $d < 2.5\ \mu\text{m}$ ) and coarse PM ( $\text{PM}_{10}$ ;  $d < 10\ \mu\text{m}$ ; HEI, 2010; Li et al., 2003; Renwick et al., 2004).

Filtration in classrooms presents some unique challenges. The older HVAC systems that exist in older schools were not designed with air filtration in mind. The classroom is a noise-sensitive environment, so filtration systems must meet strict decibel limits when in operation. Classrooms often have high ventilation rates with doors and windows that are frequently open to outside air. Finally, classrooms are large, densely occupied spaces with much activity that can lead to indoor generation of particles and other pollutants.

The main objective of this study was to investigate the effectiveness of three different air purification systems based on particle filtration and/or sorption of gaseous pollutants in reducing the exposure of children to outdoor-infiltrated air contaminants inside nine classrooms at three Southern California schools. To this end, the South Coast Air Quality Management District (SCAQMD, Diamond Bar, CA, USA) worked in close collaboration with IQAir (IQAir North America, La Mirada, CA, USA), a company that specializes in air purification solutions and with Thermal Comfort Systems (Thermal Comfort Systems Inc., Northridge, CA, USA), an HVAC contractor. Of particular interest was the removal of various sizes and types of PM, especially the smaller fractions associated with diesel engine exhaust. Solutions for removing gaseous air contaminants that may be air toxics or cause odors were also examined.

The installed systems were tested for their ability to remove UFPs,  $\text{PM}_{2.5}$ ,  $\text{PM}_{10}$ , black carbon (BC), and VOCs from the selected classrooms. UFPs are primarily produced from the combustion of fossil fuels, but indoor activities such as cooking, cleaning, painting, gluing, and drawing can also lead to sub-


stantial increases in the concentration of UFPs (Afsari, 2005; Gehin et al., 2008; Morawska et al., 2009). Fine PM is mainly emitted from motor vehicles, power plants, residential wood burning, forest fires, agricultural burning, and other combustion activities, and it has well-established health effects. Sources of  $\text{PM}_{10}$  include crushing or grinding operations, resuspension of dust from vehicles traveling on roads, and other mechanical processes. Sometimes referred to as soot, BC is related closely to elemental carbon and is a component of PM that is formed through the incomplete combustion of fossil fuels and biomass. Most of the atmospheric BC is in the fine or ultrafine particle size ranges, and the majority of BC in Southern California comes from diesel PM emissions. VOCs are comprised of gases that are emitted by a variety of evaporative processes and combustion sources, including paints, cleaning supplies, pesticides, building materials, household products, refineries, and mobile sources. Concentrations of many VOCs may be much higher indoors than outdoors (Bruno et al., 2008; Jia et al., 2007). Exposure to many of these organic contaminants has also been associated with a wide array of toxic health effects.

While several previous studies have measured indoor  $\text{PM}_{2.5}$  and  $\text{PM}_{10}$  concentrations in schools, there have been only a few reports of UFP levels in classrooms, among which only three were for works conducted in the United States (Mullen et al., 2011; Parker et al., 2008; Zhang and Zhu, 2012). However, in most cases, the effect of mechanical ventilation and air filtration performance on the measured indoor particle levels was not discussed. To the best of our knowledge, this is the first study to provide data on the effectiveness of different air filtration solutions in reducing PM, UFP, BC, and VOC concentrations in actual occupied classroom settings.

## Methods

### School and classroom characteristics

Three elementary schools (all located in Southern Los Angeles County in the Carson-Long Beach area) were selected for this study. Two of them, Del Amo Elementary and Dominguez Elementary, are part of the Los Angeles Unified School District (LAUSD), while the third school, Hudson Elementary, is part of the Long Beach Unified School District (LBUSD). All three schools are in close proximity to at least three large refineries and several heavily trafficked highways and freeways including the I-110, I-405, I-710, and CA-103 (Figure 1). The Los Angeles and Long Beach Port complexes and the Union Pacific Railroad Intermodal Container Transfer Facility (UPRR ICTF) are other major emission sources in the area. The presence of



**Fig. 1** Map of the study area. The circles indicate the locations of the three elementary schools participating in this study: Del Amo (A), Hudson (B), and Dominguez (C). The Union Pacific Railroad Intermodal Container Transfer Facility is marked by the black rectangle

these important pollution sources has lead to local concerns about the air quality in the surrounding communities.

At each of the three elementary schools, three classrooms with similar structural characteristics and ventilation conditions were selected to provide reproducible test conditions for the various air purification systems deployed. All classrooms (varying between 210 and 260 m<sup>3</sup> in size) already included forced-air HVAC systems. The main characteristics of all nine classrooms are listed in Table 1.

Prior to beginning this study, none of the selected classrooms featured any specific air purification device other than one or more medium-performance panel filters [minimum efficiency reporting value (MERV) 7] installed inside the respective HVAC systems. The typical replacement interval for these air filters is approximately 3 months according to schools' schedules. The primary purpose of this panel filter (PF) is to remove coarse particles and dust to protect the HVAC system's heating and cooling coils. These filters generally provide little or no removal of smaller particles or gaseous pollutants.

#### Air purification solutions

Three different air purification solutions were tested for their ability to remove UFPs, PM<sub>2.5</sub>, PM<sub>10</sub>, BC and, where possible, VOCs from the air stream: an HVAC-based high-performance panel filter (HP-PF), a register-based air purifier (or register system; RS), and a stand-alone system (SA). All systems were provided, installed, and maintained by IQAir.

The HP-PFs used for this study utilize a multilayered, non-woven filtration media, made of glass and synthetic fibers. The media are arranged in a 'mini-pleat' configuration, similar to that of HEPA filters used in clean-room applications. Compared to most standard/conventional medium-performance MERV filters, the HP-PFs used for this study (rated MERV 16) are twice as thick (5.08 cm in depth) and have a much larger filter surface area (5–9 times larger). Due to the increased surface area, they generally have similar air resistance properties as conventional filters and thus do not act to reduce the airflow through the HVAC system. The airflow data obtained before and after the HP-PF installation confirm this claim (see Table S2). The pressure drop of the HP-PF as specified by the manufacturer is 95 Pa at 2.5 m/s face velocity.

A RS device is installed directly on or replaces the HVAC register, where the air supply enters the room. The RS units used for this study were custom fabricated to match the size of the supply vents in each classroom and equipped with a high-performance particle filter (MERV 16) for the removal of PM and between 4 and 9 high-capacity gas-phase filter cartridges to help reduce certain gaseous pollutants from the air stream (e.g., VOCs). This particular design allows for a longer contact time between the filtration media and the gaseous pollutants than would be permitted using an activated carbon panel filter in the HVAC system. Nevertheless, the RS does not seem to reduce the overall HVAC system airflow according to our testing results (see Table S2). The gas-phase cartridges used in each RS consisted of a mixture of granular activated carbon and KMnO<sub>4</sub>-impregnated alumina pellets. Different amounts of this mixture were used (i.e., 10–22.5 kg per RS) depending on the size of the RS.

Similarly to activated carbon filters tested in previous studies (e.g., Alvarez et al., 2008), the gas-phase filter cartridges used in this RS system may also have the ability to remove ozone (O<sub>3</sub>). However, little information exists regarding the potential for this type of media to remove O<sub>3</sub> and the effect of VOC loadings on O<sub>3</sub> removal (Bekö et al., 2009; Metts and Batterman, 2006).

A SA unit is a self-contained air cleaning device that operates independently of a classroom's HVAC. The system used for this study is 1.95 m tall and has a footprint of about 0.41 m<sup>2</sup>. The SA is tamper-proof, runs on a standard power circuit, and is built with an energy efficient fan, located inside a specially designed inner housing for quiet operation. Indoor air enters from the lower part of the system (about 15 cm off the ground) and passes, sequentially, through a high-performance particle filter (MERV 16) for the removal of PM, 12 high-capacity gas-phase filter cartridges (the total media weight was 46 kg and the contact time 0.21 s) for the removal

**Table 1** Structural characteristics and ventilation conditions of the nine classrooms selected for this study

|   | Del Amo          |                  |                  | Hudson          |                 |                 | Dominguez        |                  |                  |
|---|------------------|------------------|------------------|-----------------|-----------------|-----------------|------------------|------------------|------------------|
|   | DA-6             | DA-7             | DA-8             | H-11            | H-15            | H-52            | DZ-7             | DZ-9             | DZ-11            |
| Classroom ID  | DA-6             | DA-7             | DA-8             | H-11            | H-15            | H-52            | DZ-7             | DZ-9             | DZ-11            |
| Occupants ( <i>n</i> )                                  | 18               | 19               | 22               | 21              | 11              | 17              | 28               | 28               | 29               |
| Room size (m)   | 11.6 × 7.3 × 3.0 | 11.6 × 7.3 × 3.0 | 11.6 × 7.3 × 3.0 | 9.1 × 9.1 × 2.7 | 9.1 × 9.1 × 2.7 | 9.4 × 8.2 × 2.7 | 11.6 × 6.7 × 3.4 | 11.6 × 6.7 × 3.4 | 11.6 × 6.7 × 3.4 |
| HVAC type   | DW-M             | DW-M             | DW-M             | DM-ZR           | DM-ZR           | DR              | DR               | DR               | DR               |
| HVAC operation  | Manual           | Manual           | Manual           | Automatic       | Automatic       | Automatic       | Manual           | Manual           | Manual           |
| Supplied airflow <sup>a</sup> (m <sup>3</sup> /h)       | 2039             | 2039             | 2124             | 1427            | 1534            | 2100            | 2790             | 2856             | 3011             |
| Return airflow <sup>a</sup> (m <sup>3</sup> /h)         | 1546             | 850              | 1223             | 1359            | 1461            | 1665            | 2200             | 1623             | 2234             |
| Mechanical ventilation <sup>a</sup> (m <sup>3</sup> /h) | 493              | 1189             | 901              | 68              | 73              | 435             | 590              | 1233             | 777              |
| Filtration rate <sup>b</sup> (per hour)                 | 8.0              | 8.0              | 8.4              | 6.4             | 6.9             | 10.1            | 10.6             | 10.8             | 11.4             |
| Filter type   | Pleated          | Pleated          | Pleated          | Pleated         | Pleated         | Fiberglass      | Pleated          | Pleated          | Pleated          |
| Filter thickness (cm)                                   | 5.08 (2")        | 5.08 (2")        | 5.08 (2")        | 5.08 (2")       | 5.08 (2")       | 5.08 (2")       | 2.54 (1")        | 2.54 (1")        | 2.54 (1")        |
| Filter rating   | MERV 7           | MERV 7           | MERV 7           | MERV 7          | MERV 7          | Unclassified    | MERV 7           | MERV 7           | MERV 7           |
| Supply vents ( <i>n</i> )                               | 1 (wall)         | 1 (wall)         | 1 (wall)         | 1 (ceiling)     | 1 (ceiling)     | 4 (ceiling)     | 3 (ceiling)      | 3 (ceiling)      | 3 (ceiling)      |
| Return grille ( <i>n</i> )                              | 1 (wall)         | 1 (wall)         | 1 (wall)         | 1 (ceiling)     | 1 (ceiling)     | 1 (ceiling)     | 1 (ceiling)      | 1 (ceiling)      | 1 (ceiling)      |

DW-M: ducted wall-mount; DM-ZR, ducted multizone rooftop; DR, ducted rooftop; HVAC, heating, ventilating, and air conditioning; MERV, minimum efficiency reporting value.

A balometer was used for all airflow measurements.

<sup>a</sup>With existing panel filter.

<sup>b</sup>Supplied airflow/room volume.



of VOCs and other gaseous pollutants commonly found indoors, and a final high-performance particle post-filter. When operated at  $1362 \text{ m}^3/\text{h}$  (as during this study), this SA unit has a power draw of 157 W and complies with the stringent noise requirements for new in-classroom equipment adopted by many schools [45 db(A) noise threshold].


## In-classroom configurations

Different combinations of the HVAC-based HP-PF, RS air purifier, and SA system were used inside the studied classrooms to evaluate their performance under occupied conditions. Specifically, the following configurations were used: (1) HP-PF alone; (2) RS alone, although in some cases it was operated in combination with the conventional/medium-performance PF (MERV 7) already installed inside the HVAC prior to the beginning of the study (RS + PF); (3) RS in conjunction with a HP-PF (RS + HP-PF); (4) SA system in classrooms with no HVAC running; (5) SA system in classrooms with an HVAC running, in which case a conventional/medium-performance PF (MERV 7) was already installed inside the HVAC (SA + PF); (6) SA system in conjunction with a HP-PF (SA + HP-PF). A

schematic representation of these six configurations is shown in Figure 2.

## Indoor and outdoor measurements

Four mobile air quality monitoring stations were used to measure the indoor and outdoor concentrations of the targeted air pollutants. Each of these stations was comprised of a mobile cart supporting the following instruments: (i) a *portable aethalometer* (model AE42; Magee Scientific, CA, USA) for the continuous measurements (i.e., 5-min time resolution) of BC concentrations ( $\text{ng}/\text{m}^3$ ); (ii) a *water-based condensation particle counter* (CPC model 3781; TSI, MN, USA) for the continuous measurements (i.e., 1-min time resolution) of the particle number concentration ( $n/\text{cm}^3$ ), an indicator of UFPs; (iii) a *laser particle counter* (IQAir ParticleScan Pro) for determining the number concentration ( $n/\text{cm}^3$ ) of particles between  $0.3$  and  $2.5 \mu\text{m}$  in diameter [ $\text{PM}_{(0.3-2.5)}$ ] at 1-min time resolution; (iv) a *laser-based particle mass monitor* (Aerocet 531 Aerosol Particulate Profiler; MetOne, OR, USA) for the continuous measurements (i.e., 3-min time resolution) of the mass concentration ( $\mu\text{g}/\text{m}^3$ ) of both  $\text{PM}_{2.5}$  and  $\text{PM}_{10}$ ; and (v)



**Fig. 2** Schematic representation of the six air purification solutions tested in this study. Different combinations of the heating, ventilating, and air conditioning (HVAC)-based high-performance panel filter (HP-PF), register-based air purifier (RS) air purifier, and standalone system (SA) system were used inside the studied classrooms to evaluate their performance

6-liter SUMMA<sup>®</sup> canisters to collect time-integrated air samples over the course of a typical school day (i.e., 6-h). Samples were then analyzed by Gas Chromatography-Mass Spectrometry (GC-MS) to measure the concentrations of 61 specific VOCs (ppbv) using the TO-15 method developed by the Environmental Protection Agency (1999).

At each school, one air quality monitoring cart was set up outside to sample outdoor air. The remaining three stations were placed indoors, one in each classroom, near one of the walls and just a few meters away from the students. Measurements were made away from all air conditioning vents to better represent mixed Indoor Air Quality conditions as experienced by students and teachers. All sensors and inlets were approximately 90 cm above the floor or about the height of a child's head when seated. The performance of each of the tested air purification solutions was then evaluated by comparing the indoor concentrations of the targeted air pollutants to the corresponding outdoor levels. Baseline measurements were taken before installing any of the air purification solutions to estimate the preexisting removal effectiveness of the classrooms before modification. Measurements that were found to be inaccurate or unrepresentative due to meteorological conditions (e.g., rain), improper cart placement, or instrument malfunction were not considered in the data analysis.

Before and after school hours, the four measurement stations were collocated in a storage room and the continuous instruments were run 'side-by-side' to provide quality assurance of the collected data, to estimate the precision characteristics, and to identify any potential problems. The accuracy of the colocated measurements from the four sets of instruments used during this study was always within 5%. Instruments that failed were identified for immediate repair, and their data for that monitoring period removed from the analysis. Table 2 illustrates the specific air purification solutions that were tested inside each of the nine classrooms, along with the dates when all baseline and actual measurements were taken. The three schools were tested one at a time from April to December 2008 for a total of over 150 valid measurement days across all schools and classrooms. The number of measurement days at each school is shown in Table 4. The period of sampling was during regularly scheduled school hours (from 09:00 to 15:00), with minor adjustments for school schedule changes, and in actual occupied classroom settings.

A balometer was used to measure the airflow at both the supply vent and the return register before and after the installation of the RS and/or HP-PF. The mechanical ventilation rate for each classroom was calculated as the difference between the supply and return airflows (Table 1).

**Table 2** Summary of the air purification solutions tested in each of the nine classrooms. The dates when all baseline and actual measurements were taken are also included

| School/Class ID | Configuration used |             |             |                   |
|-----------------|--------------------|-------------|-------------|-------------------|
|                 | 04/07–11/08        | 04/14–18/08 | 04/21–25/08 | 04/28/08–05/02/08 |
| Del Amo/DA-6    | Baseline           | SA + PF     | SA + PF     | SA + HP-PF        |
| Del Amo/DA-7    | Baseline           | RS          | RS          | RS                |
| Del Amo/DA-8    | Baseline           | HP-PF       | HP-PF       | HP-PF             |
|                 | 05/12–16/08        | 05/19–23/08 | 05/26–30/08 | 06/02–06/08       |
|                 |                    |             |             |                   |
| Hudson/H-11     | Baseline           | HP-PF       | RS + HP-PF  | RS + HP-PF        |
| Hudson/H-15     | Baseline           | HP-PF       | RS + HP-PF  | RS + HP-PF        |
| Hudson/H-52     | Baseline           | HP-PF       | RS + HP-PF  | RS + HP-PF        |
|                 | 11/18–26/08        | 12/01–05/08 | 12/08–12/08 | 12/15–19/08       |
|                 |                    |             |             |                   |
| Dominguez/DZ-7  | Baseline           | SA/SA + PF  | SA + HP-PF  | SA + HP-PF        |
| Dominguez/DZ-9  | Baseline           | HP-PF       | HP-PF       | HP-PF             |
| Dominguez/DZ-11 | Baseline           | HP-PF       | RS + HP-PF  | RS + HP-PF        |

HP-PF, HVAC-based high-performance panel filter; HVAC, heating, ventilating, and air conditioning; RS, register-based air purifier; SA, stand-alone system; PF, conventional/medium efficiency panel filter.

## Results and discussion

### Removal of PM and other particle species

Study average outdoor BC, UFP, PM<sub>2.5</sub>, and PM<sub>10</sub> levels at all schools were similar to those seen throughout the South Coast Air Basin (SCAB) during previous monitoring campaigns conducted by SCAQMD and represent typical outdoor conditions for most urban areas of SCAB (Table 3). Differences in measured outdoor concentrations among the three school sites are mainly due to different proximity to local emission sources and temporal variability. Daily and weekly average indoor and outdoor concentrations of the measured pollutants at all schools and classrooms are provided in Table S1, along with the corresponding average indoor/outdoor ratios.


Figure 3 and Table 4a summarize the study average particle removal effectiveness (or removal performance, here defined as the percentage reduction in the indoor concentration of a particular pollutant relative to its concurrent outdoor concentration) achieved by the six air purification solutions. Indoor and outdoor mass and particle number concentrations were averaged over the duration of a typical school day and across all days, classrooms, and schools. The corresponding average particle removal effectiveness values for each elementary school are reported in Tables 4b (Del Amo), 4c (Hudson), and 4d (Dominguez).

Overall, the RS + HP-PF combination was the most effective solution for reducing the indoor concentrations of BC, UFPs, PM<sub>2.5</sub> mass, and PM<sub>(0.3–2.5)</sub> count, with average removal effectiveness varying from 87% to 96% (Figure 3 and Table 4a). When using the HP-PF alone, the study average removal performance for

**Table 3** Summary statistics for the outdoor BC, UFPs,  $PM_{(0.3-2.5)}$  count,  $PM_{2.5}$  mass, and  $PM_{10}$  concentrations measured at all schools

|           | BC ( $\mu\text{g}/\text{m}^3$ ) | UFP ( $n/\text{cm}^3$ ) | $PM_{(0.3-2.5)}$ count ( $n/\text{cm}^3$ ) | $PM_{2.5}$ mass ( $\mu\text{g}/\text{m}^3$ ) | $PM_{10}$ mass ( $\mu\text{g}/\text{m}^3$ ) |
|-----------|---------------------------------|-------------------------|--|--|---|
| Del Amo   |                                 |                         |  |  |   |
| Average   | 2.24                            | 40 354                  | 56   | 10.9   | 39.6  |
| Median    | 1.69                            | 38 854                  | 53   | 10.8   | 41.1  |
| s.d.      | 1.22                            | 9920                    | 22   | 3.25   | 10.8  |
| Min       | 0.95                            | 19 124                  | 21   | 5.61   | 5.61  |
| Max       | 4.45                            | 57 526                  | 117  | 17.9   | 55.5  |
| Hudson    |                                 |                         |  |  |   |
| Average   | 1.53                            | 38 174                  | 42   | 11.9   | 51.8  |
| Median    | 1.14                            | 38 368                  | 41   | 12.7   | 48.8  |
| s.d.      | 0.86                            | 15 434                  | 19   | 6.73   | 23.4  |
| Min       | 0.73                            | 14 643                  | 13   | 2.34   | 18.7  |
| Max       | 3.76                            | 80 163                  | 74   | 29.0   | 99.0  |
| Dominguez |                                 |                         |  |  |   |
| Average   | 5.43                            | 28 922                  | 193  | 12.7   | 44.4  |
| Median    | 4.67                            | 29 061                  | 221  | 11.0   | 46.7  |
| s.d.      | 2.72                            | 8566                    | 122  | 9.72   | 20.7  |
| Min       | 1.98                            | 16 048                  | 15   | 1.29   | 7.99  |
| Max       | 11.2                            | 42 651                  | 364  | 35.3   | 86.1  |

BC, black carbon; PM, particulate matter; UFP, ultrafine particles.



**Fig. 3** Particle removal effectiveness values (%) achieved by the six air purification solutions. Bars indicate data averaged at all schools and in all classrooms. Vertical lines represent standard deviations for each bar

the targeted pollutants was also close to 90% (88%, 86%, 91%, and 88%, for BC, UFPs,  $PM_{(0.3-2.5)}$  count, and  $PM_{2.5}$  mass, respectively).

The SA system is well suited for indoor environments not equipped with an HVAC. To simulate conditions similar to those encountered in older classrooms not equipped with a forced-air climate control device, the HVAC in room DZ-7 (at Dominguez) was intentionally turned off for part of the study. When the SA unit was running with the HVAC off, the removal effectiveness was close to 90% for BC, UFPs, and  $PM_{(0.3-2.5)}$  count (Table 4d). For BC and UFPs, these percentages were slightly lower when the HVAC was

running because more of the smaller particles (mostly unfiltered by the existing conventional PF) were entering the classrooms from outdoors. It should be noted that the performance of a SA system is likely to be affected by the proximity of the device to doors, windows and air supply registers, the lower airflow rate ‘processed’ by the SA unit relative to the flow rate handled by the HVAC system (i.e., lower Clean Air Delivery Rate; Zhang et al., 2011), and other factors intrinsic to the particular classroom setup considered.

In all cases, air quality conditions were improved substantially with respect to the corresponding baseline measurements, when removal effectiveness values for

**Table 4** Particle removal effectiveness values (%) achieved by the six air purification solutions tested in this study. Data represent averages (a) at all schools and in all classrooms, (b) at Del Amo, (c) at Hudson, and (d) at Dominguez

|                                    | Study days (n) | BC (%)  | UFP (%) | PM <sub>(0.3-2.5)</sub> count (%) | PM <sub>2.5</sub> mass (%) | PM <sub>10</sub> mass (%) |
|------------------------------------|----------------|---------|---------|-----------------------------------|----------------------------|---------------------------|
| (a) All classrooms and all schools |                |         |         |                                   |                            |                           |
| Baseline                           | 48             | 22 ± 13 | 52 ± 17 | 45 ± 14                           | 37 ± 26                    | 13 ± 36                   |
| SA + PF <sup>a</sup>               | 14             | 67 ± 6  | 77 ± 6  | 79 ± 5                            | 75 ± 5                     | 59 ± 9                    |
| SA + HP-PF                         | 11             | 91 ± 6  | 93 ± 4  | 90 ± 3                            | 82 ± 12                    | 53 ± 33                   |
| RS + PF                            | 15             | 74 ± 20 | 81 ± 10 | 79 ± 17                           | 69 ± 24                    | 22 ± 46                   |
| RS + HP-PF                         | 35             | 95 ± 2  | 96 ± 3  | 93 ± 5                            | 87 ± 11                    | 42 ± 28                   |
| HP-PF                              | 35             | 88 ± 5  | 86 ± 7  | 91 ± 4                            | 88 ± 8                     | 53 ± 31                   |
| (b) Del Amo elementary school      |                |         |         |                                   |                            |                           |
| Baseline                           | 15             | 8 ± 9   | 45 ± 16 | 18 ± 20                           | 27 ± 17                    | 26 ± 26                   |
| SA + PF <sup>a</sup>               | 10             | 52 ± 7  | 68 ± 6  | 60 ± 7                            | 64 ± 5                     | 51 ± 9                    |
| SA + HP-PF                         | 5              | 90 ± 5  | 92 ± 3  | 93 ± 1                            | 91 ± 4                     | 74 ± 11                   |
| RS + PF                            | 15             | 74 ± 20 | 81 ± 10 | 79 ± 17                           | 69 ± 24                    | 22 ± 46                   |
| HP-PF                              | 15             | 88 ± 4  | 87 ± 4  | 89 ± 5                            | 89 ± 5                     | 62 ± 13                   |
| (c) Hudson elementary school       |                |         |         |                                   |                            |                           |
| Baseline                           | 15             | 33 ± 9  | 56 ± 18 | 46 ± 11                           | 74 ± 5                     | 54 ± 23                   |
| RS + HP-PF                         | 27             | 96 ± 2  | 98 ± 2  | 94 ± 4                            | 94 ± 5                     | 51 ± 30                   |
| HP-PF                              | 15             | 92 ± 2  | 91 ± 4  | 93 ± 2                            | 93 ± 4                     | 59 ± 33                   |
| (d) Dominguez elementary school    |                |         |         |                                   |                            |                           |
| Baseline                           | 18             | 24 ± 21 | 54 ± 16 | 70 ± 11                           | 11 ± 55                    | -42 ± 60                  |
| SA <sup>b</sup>                    | 3              | 90 ± 4  | 94 ± 2  | 92 ± 6                            | 75 ± 10                    | 31 ± 42                   |
| SA + PF <sup>a</sup>               | 4              | 82 ± 5  | 86 ± 5  | 97 ± 2                            | 86 ± 4                     | 66 ± 8                    |
| SA + HP-PF                         | 6              | 91 ± 6  | 94 ± 4  | 87 ± 5                            | 72 ± 20                    | 32 ± 55                   |
| RS + HP-PF                         | 8              | 94 ± 2  | 94 ± 3  | 91 ± 6                            | 80 ± 17                    | 33 ± 25                   |
| HP-PF                              | 18             | 85 ± 8  | 81 ± 13 | 91 ± 5                            | 81 ± 16                    | 39 ± 48                   |

BC, black carbon; HP-PF, HVAC-based high-performance panel filter; HVAC, heating, ventilating, and air conditioning; PM, particulate matter; RS, register-based air purifier; SA, stand-alone system; MERV, minimum efficiency reporting value; UFP, ultrafine particles.


<sup>a</sup>Operated in conjunction with a standard (MERV 7) panel filter installed in the HVAC system.

<sup>b</sup>The HVAC system was turned off.

the different pollutants were typically between 20% and 50% (Table 4a). The intraclassroom variability of the measured removal effectiveness data was low, as indicated by the low standard deviations given in Table 4a. This reflects the fact that all air purification solutions were characterized by high performance at all schools and in all classrooms.

The negative removal effectiveness for PM<sub>10</sub> associated with average baseline conditions at Dominguez (see Table 4d) indicates that, at times, indoor concentrations were higher than the corresponding outdoor levels. This is likely due to resuspension of dust and other relatively large particles caused by in-classroom activities such as walking and cleaning (Branis et al., 2005; Parker et al., 2008). Due to the presence of these indoor sources, the removal performance of PM<sub>10</sub> was lower than that of other particle measurements. Typically, the removal effectiveness for PM<sub>10</sub> approached 100% right before the school day started and during lunchtime (when students and staff members were outside the classroom and the HVAC was running) and was substantially lower when classes were in session. The effect of indoor activities on PM<sub>10</sub> levels inside classroom H-15 (Hudson elementary) on May 21, 2008 is illustrated in Figure 4.


Activities occurring immediately outside the school boundaries also influenced the indoor concentrations of



**Fig. 4** Effect of indoor activities on the removal performance of PM<sub>10</sub> at Hudson elementary school (room H-15) on May 21, 2008. PM, particulate matter

some pollutants and thus their corresponding removal performance values. Figure 5 shows the effect of increased motor vehicle emissions due to the morning drop-off of students (starting at approximately 07:30 AM) on the outdoor concentrations of BC and the associated spikes in indoor BC levels occurring just before the beginning of the school day, when the





**Fig. 5** Effect of before school activities on black carbon (BC) concentrations. Early morning (preschool) peaks at Hudson elementary school show an increase in both indoor (rooms H-11, H-15, and H-52) and outdoor levels due to morning drop-off traffic

classroom doors were left open. Overall, these indoor peaks caused a relatively small decrease in the calculated removal performance when averaged over the course of the entire school day. Similar results were also observed for UFPs and  $PM_{(0.3-2.5)}$  and are consistent with data collected in other classroom environments (Guo et al., 2010), where human activities such as cigarette smoking and the operation of mower near the school sites have also been related to sudden increases in the outdoor and indoor levels of these pollutants.

As discussed earlier, the HP-PFs used for this study are deeper than most standard/conventional medium-performance MERV filters. However, due to their increased surface area and proprietary design, they generally have similar air resistance properties as conventional PF and thus do not reduce the airflow through the HVAC system. Replacing a conventional PF (typically 2.54 cm in depth) with a deeper HP-PF (5.08 cm deep) did not alter the measured airflow in any of the studied classrooms substantially (see Table S2 for details). Adding a RS without upgrading to a HP-PF reduced the HVAC system airflow by an average of 9%. This small reduction is due to the increased pressure drop resulting from the addition of a gas-phase filtration media. Using a RS while also upgrading to a HP-PF (RS + HP-PF configuration) altered the airflow by only 1–3%. At Hudson elementary school, installation of the RS in classrooms H-11 and H-15 required a widening of the connection to the supply duct. This caused an airflow increase between 17% and 24% with RS. Data showing the effect of the HP-PF and/or RS on the HVAC system airflow at all schools and in all classrooms can be found in Table S2.

## Removal of VOCs

Although canister samples were collected at all schools and classrooms and all samples were analyzed for VOCs, the data recovery at Del Amo and Hudson was insufficient to guarantee an adequate interpretation of the results. The detection limits of the analysis method used at those schools were not low enough to quantify most of the VOCs of interest. After the analysis methods were modified to correct for this problem, reliable VOC data were obtained for Dominguez elementary. Therefore, only VOC data from Dominguez are discussed in this section. Table 5 summarizes the removal effectiveness for: total VOCs [expressed as the sum of 61 individual compounds and 53 unspiciated (unidentified) organic compounds], ethanol (a chemical emitted from both indoor and outdoor evaporative sources), and benzene (a species mostly emitted from gasoline-powered vehicles and often used as an indicator of VOCs of outdoor origin). Large standard deviations reflect the wide concentration ranges for the different chemicals. As expected, existing PF and HP-PFs had virtually no effect on the VOC levels measured indoors, because these air filtration media did not include gas removal capabilities. The SA system demonstrated a 52–73% removal performance for benzene. Daily average concentrations of individual VOCs measured at Dominguez elementary school (i.e., DZ-7, DZ-9, and DZ-11) are given in Table S3.

At all three schools, the indoor concentrations of ethanol were consistently the highest among all measured VOCs and higher than outdoor levels. This organic compound is a common solvent used in white-board markers, detergents, and other cleaning products and has several potential indoor sources. The negative removal effectiveness values shown in Table 5 indicate that the indoor concentrations of some VOCs were often higher than the corresponding outdoor levels. Our findings are in line with those from previous research studies (Bruno et al., 2008; Jia et al., 2007)

**Table 5** Average removal effectiveness for total volatile organic compounds (VOCs), ethanol, and benzene at Dominguez

| Dominguez                      |                |                             |              |             |
|--------------------------------|----------------|-----------------------------|--------------|-------------|
|                                | Study days (n) | Total VOCs (%) <sup>a</sup> | Ethanol (%)  | Benzene (%) |
| Baseline                       | 18             | −114 ± 731                  | −1230 ± 982  | −11 ± 22    |
| SA (HVAC off) <sup>b</sup>     | 3              | 15 ± 132                    | −349 ± 276   | 52 ± 35     |
| SA + PF (HVAC on) <sup>c</sup> | 4              | 19 ± 198                    | −587 ± 903   | 58 ± 33     |
| SA + HP-PF                     | 6              | −6 ± 280                    | −929 ± 853   | 73 ± 11     |
| RS + HP-PF                     | 8              | −3 ± 345                    | −534 ± 502   | 58 ± 49     |
| HP-PF                          | 18             | −64 ± 404                   | −1111 ± 1164 | 1 ± 38      |

HP-PF, HVAC-based high-performance panel filter; HVAC, heating, ventilating, and air conditioning; RS, register-based air purifier; SA, stand-alone system; VOCs, volatile organic compounds.

<sup>a</sup>Sum of 61 known VOCs and 53 unspiciated organic compounds.

<sup>b</sup>Operated with the HVAC system turned off.

<sup>c</sup>Operated with the HVAC system turned on.

and confirm that several measured indoor VOCs are mostly of indoor origin. Overall, these solutions demonstrated some ability to reduce VOCs indoors, although not as consistently or effectively as the particle filtration. This may be due to the presence of one or more indoor sources of gaseous pollutants. It should be noted that the removal performance of gas-absorbing media (as opposed to filtration substrates) is dependent on media history and may be subject to saturation after experiencing high short-term concentrations or after longer-term use. Also, the organic compounds captured by the gas-phase filter cartridges (as well as those associated with the particles removed on the filter surface) may then undergo chemical transformation and/or desorb into the airstream, further degrading air quality downstream of the air cleaning device (Bekö et al., 2006, 2008; Weschler, 2004). Relative humidity has also been shown to impact the ability of activated carbon filters to remove VOCs. The extent of such impact varies depending on the VOC type (i.e., hydrophobic or hydrophilic) and concentration and the type of activated carbon used (Haghighat et al., 2008; Qi et al., 2006).

As observed by Zhang et al. (2011) in a recent literature review paper on fan-driven air cleaning technologies, sorption is an efficient technology for removing specific gaseous pollutants such as certain VOCs, formaldehyde, O<sub>3</sub>, NO<sub>2</sub>, SO<sub>2</sub>, and H<sub>2</sub>S from the indoor air. However, the removal effect for multiple indoor compounds remains unknown, and for a target pollutant, the criteria for selecting the best sorption material to optimize removal over a given time period are generally not available (Zhang et al., 2011). The lifetime, cost, benefits, and maintenance of the gas removal media used in this study must be further assessed before conclusions and recommendations can be made.

## Conclusions

An HVAC-based high-performance panel filter (HP-PF; rated MERV 16), a register-based air purifier (RS), and a stand-alone system (SA) were tested alone and in different combinations for their ability to remove particle and gaseous pollutants from classroom environments. When used alone, the study average HP-PF removal effectiveness for BC, UFPs, and PM<sub>2.5</sub> mass was 86–88%. The removal performance was even higher (i.e., 87–96%) when the same HP-PF was coupled with a RS. Removal effectiveness values for BC and UFPs close to 90% were also measured for the SA system, both when this was used in conjunction with a HP-PF and when the HVAC was turned off. Data on the ability of these technologies to remove VOCs were inconclusive.

Although most of the legislative efforts should focus on ambient PM reduction policies, the installa-

tion of highly effective air filtration devices in schools may be an important mitigation measure to minimize exposure of children to indoor pollutants of outdoor origin, especially at schools located near heavily trafficked freeways, refineries, and other important sources of air toxics. Future research should focus on (i) identifying additional technologies for the removal of indoor air pollutants (VOCs in particular), (ii) quantifying the short- and long-term impact of installing highly effective air filtration devices in schools on children's health, productivity, and absenteeism, and (iii) the cost benefits resulting from improved Indoor Air Quality conditions and from a reduction in student exposure to outdoor-infiltrated particles and organic pollutants.

## Acknowledgements

This study was funded through the use of mitigation fees collected by SCAQMD under Rule 1172 for VOC releases by local refineries. The SCAQMD is the air pollution control agency for all of Orange County and urban portions of Los Angeles, Riverside, and San Bernardino counties. IQAir North America, Inc., a leading specialist in air filtration solutions for homes, hospitals, and schools, and Thermal Comfort Systems, specialist in HVAC system design, were selected by SCAQMD through a competitive bid process to provide for the design, engineering, and installation of the air filtration devices used for this work. The SCAQMD would like to thank Dr. Michael Geller (U.S. EPA) for contributing to the success of this project.

## Disclaimer

The mention of commercial products, their source, or their use in connection with material reported herein is not to be construed as actual or implied endorsement of such products by the authors or by the SCAQMD.

## Supporting Information

Additional Supporting Information may be found in the online version of this article:

**Table S1** Daily and weekly average indoor and outdoor concentrations of BC, UFP, PM<sub>(0.3–2.5)</sub> count, PM<sub>2.5</sub> mass, and PM<sub>10</sub> mass at all schools and classrooms.

**Table S2** Effect of a high-performance panel filter (HP-PF) and/or a register system (RS) on the HVAC supplied airflow.

**Table S3** Daily average concentrations of individual VOCs measured outside Dominguez elementary school and inside three of its classrooms (here referred to as DZ-7, DZ-9, and DZ-11).

## References

- Afshari, A. (2005) Characterization of indoor sources of fine and ultrafine particles: a study conducted in a full-scale chamber, *Indoor Air*, **15**, 141–150.
- Alvarez, P.M., Masa, F.J., Jaramillo, J., Beltran, F.J. and Gomez-Serrano, V. (2008) Kinetics of ozone decomposition by granular activated carbon, *Ind. Eng. Chem. Res.*, **47**, 2545–2553.
- Bekö, G., Halás, O., Clausen, G. and Weschler, C.J. (2006) Initial studies of oxidation processes on filter surfaces and their impact on perceived air quality, *Indoor Air*, **16**, 56–64.
- Bekö, G., Clausen, G. and Weschler, C.J. (2008) Sensory pollution from bag filters, carbon filters and combinations, *Indoor Air*, **18**, 27–36.
- Bekö, G., Fadeyi, M.O., Clausen, G. and Weschler, C.J. (2009) Sensory pollution from bagtype fiberglass ventilation filters: conventional filter compared with filters containing various amounts of activated carbon, *Build. Environ.*, **44**, 2114–2120.
- Benbrahim-Tallaa, L., Baan, R.A., Grosse, Y., Lauby-Secretan, B., El Ghissassi, F., Bouvard, V., Guha, N., Loomis, D. and Straif, K. (2012) Carcinogenicity of diesel-engine and gasoline-engine exhausts and some nitroarenes, *Lancet Oncol.*, Early Online Publication, doi: 10.1016/S1470-2045(12)70280-2, Available at: [http://www.thelancet.com/journals/lanonc/article/PIIS1470-2045\(12\)70280-2/fulltext](http://www.thelancet.com/journals/lanonc/article/PIIS1470-2045(12)70280-2/fulltext).
- Branis, M., Rezacova, P. and Domasova, M. (2005) The effect of outdoor air and indoor human activity on mass concentrations of PM<sub>10</sub>, PM<sub>2.5</sub>, and PM<sub>1</sub> in a classroom, *Environ. Res.*, **99**, 143–149.
- Bruno, P., Caselli, M., De Gennaro, G., Iacobellis, S. and Tutino, M. (2008) Monitoring of volatile organic compounds in non-residential indoor environments, *Indoor Air*, **18**, 250–256.
- Environmental Protection Agency (1999) *Compendium of Methods for Toxic Air Pollutants, Second Edition, Method TO-15*, Center for Environmental Research Information, Office of Research and Development.
- Environmental Protection Agency Integrated Science Assessments (External Review Draft; 2009) Available at: <http://cfpub.epa.gov/ncea/cfm/recorddisplay.cfm?deid=201805>.
- Gehin, E., Ramalho, O. and Kirchner, S. (2008) Size distribution and emission rate measurement of fine and ultrafine particle from indoor human activities, *Atmos. Environ.*, **42**, 8341–8352.
- Guo, H., Morawska, L., He, C.R., Zhang, Y.L.L., Ayoko, G., Cao, M. and Cao, M. (2010) Characterization of particle number concentrations and PM<sub>2.5</sub> in a school: influence of outdoor air pollution on indoor air, *Environ. Sci. Pollut. Res.*, **17**, 1268–1278.
- Haghighat, F., Lee, C.-S., Pant, B., Bolourani, G., Ness, L. and Bastani, A. (2008) Evaluation of various activated carbons for air cleaning – Towards design of immune and sustainable buildings, *Atmos. Environ.*, **42**, 8176–8184.
- Health Effects Institute (2010) Traffic-related air pollution: a critical review of the literature on emissions, exposure, and health effects, Available at: <http://pubs.healtheffects.org/>.
- Jia, C., Batterman, S. and Godwin, C. (2007) VOCs in industrial, urban and suburban neighborhoods, Part 1: indoor and outdoor concentrations, variation, and risk drivers, *Atmos. Environ.*, **42**, 2083–2100.
- Li, N., Sioutas, C., Cho, A., Schmitz, D., Misra, C., Sempf, J., Wang, M.Y., Oberley, T., Froines, J. and Nel, A. (2003) Ultrafine particulate pollutants induce oxidative stress and mitochondrial damage, *Environ. Health Perspect.*, **111**, 455–460.
- Liu, L., Poon, R., Chen, L., Frescura, A.M., Montuschi, P., Ciabattini, G., Wheeler, A. and Dales, R. (2009) Acute Effects of Air Pollution on Pulmonary Function, Airway Inflammation, and Oxidative Stress in Asthmatic Children, *Environ. Health Perspect.*, **117**, 668–674.
- Metts, T.A. and Batterman, S.A. (2006) Effect of VOC loading on the ozone removal efficiency of activated carbon filters, *Chemosphere*, **62**, 34–44.
- Morawska, L., He, C.R., Johnson, G., Guo, H., Uhde, E. and Ayoko, G. (2009) Ultrafine particles in indoor air of a school: possible role of secondary organic aerosols, *Environ. Sci. Technol.*, **43**, 9103–9109.
- Mullen, N.A., Bhangar, S., Hering, S.V., Kreisberg, N.M. and Nazaroff, W.W. (2011) Ultrafine particle concentrations and exposures in six elementary school classrooms in northern California, *Indoor Air*, **21**, 77–87.
- Parker, J.L., Larson, R.R., Eskelson, E., Wood, E.M. and Veranth, J.M. (2008) Particle size distribution and composition in a mechanically ventilated school building during air pollution episodes, *Indoor Air*, **18**, 386–393.
- Patel, M.M. and Miller, R.L. (2009) Air pollution and childhood asthma: recent advances and future directions, *Curr. Opin. Pediatr.*, **21**, 235–242.
- Pope, C.A. and Dockery, D.W. (2006) Health effects of fine particulate air pollution: lines that connect, *J. Air Waste Manag. Assoc.*, **56**, 709–742.
- Qi, N., Appel, S., LeVan, M.D. and Finn, J. E. (2006) Adsorption dynamics of organic compounds and water vapour in activated carbon beds, *Ind. Eng. Chem. Res.*, **45**, 2303–2314.
- Renwick, L.C., Brown, D., Clouter, A. and Donaldson, K. (2004) Increased inflammation and altered macrophage chemotactic responses caused by two ultrafine particle types, *Occup. Environ. Med.*, **61**, 442–447.
- Schwartz, J. (2004) Air pollution and children's health, *Pediatrics*, **113**, 1037–1043.
- South Coast Air Quality Management District (2008), MATES III Study, Available at: <http://www.aqmd.gov/prdas/matesIII/matesIII.html>.
- Weschler, C.J. (2004) Chemical reactions among indoor pollutants: what we've learned in the new millennium, *Indoor Air*, **14**(Suppl. 7), 184–194.
- Wiley, J.A., Robinson, J.P., Cheng, Y.T., Piazza, T., Stork, L. and Pladsen, K. (1991) *Study of Children's Activity Patterns, Final Report*, Contract No. A733-149, Sacramento, CA, California Air Resources Board.
- Zhang, Q. and Zhu, Y. (2012) Characterizing ultrafine particles and other air pollutants at five schools in South Texas, *Indoor Air*, **22**, 33–42.
- Zhang, Y., Mo, J., Li, Y., Sundell, J., Wargocki, P., Zhang, J., Little, J.C., Corsi, R., Deng, Q., Leung, M.H.K., Fang, L., Chen, W., Li, J. and Sun, Y. (2011) Can commonly-used fan-driven air cleaning technologies improve indoor air quality? A literature review, *Atmos. Environ.*, **45**, 4329–4343.